

Certificate of Compliance

Certificate: 2337842

Master Contract: 232867

Project: 2337842

Date Issued: November 22, 2010

Issued to: Leuze Electronic GmbH & Co. KG
Liebigstrasse 4
82256 Fürstentfeldbruck
GERMANY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



G. Foulem
Issued by: G. Foulem

PRODUCTS

CLASS 3211 07 – Industrial control equipment - Miscellaneous Apparatus

CLASS 3211 87 – Industrial control equipment - Miscellaneous Apparatus – Certified to US standards

Light Curtain System, Multiple Light Beam Device, MLD 300 and MLD 500 series

	Power Supply	Output	Enclosure Type
MLD 3..- .T..	24Vdc, 50mA	-	CSA Enclosure Type 1
MLD 5..- .T..	24Vdc, 50mA	-	CSA Enclosure Type 1
MLD 3..- .R..	24Vdc, 150mA (without load)	24Vdc, 2 x 300mA (Resistive)	CSA Enclosure Type 1
MLD 5..- .R..	24Vdc, 150mA (without load)	24Vdc, 2 x 300mA (Resistive)	CSA Enclosure Type 1
MLD 3..-RT..	24Vdc, 150mA (without load)	24Vdc, 2 x 300mA (Resistive)	CSA Enclosure Type 1
MLD 5..-RT..	24Vdc, 150mA (without load)	24Vdc, 2 x 300mA (Resistive)	CSA Enclosure Type 1

Note:

1. Cat. No. may be completed with suffixes that indicate the type of device and functional variations.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0 – 10 - General Requirements

CSA Standard C22.2 No. 14 – 10 - Industrial Control Equipment

UL Standard UL 508, Ed. 17 - Industrial Control Equipment



Supplement to Certificate of Compliance

Certificate: 2337842

Master Contract: 232867

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2337842	November 22, 2010	Original Certification of Light Curtain System MLD300 and MLD500 series.